

	A	B	C	D	E
1	HW-18				
2	Ex. 6-PII				
3		Analyte		Result	Trigger
4		Sodium	Wellhead	45,600 ug/L	20,000 ug/L
5		Sodium	Tap	37,000 ug/L	20,000 ug/L
6	EPA Alt. Water	No			
7	Cabot Alt. Water	No (Previously-until 9/10)			
8	Treatment	Yes-2 sediment filters only			
9	Proposed EPA Water	No			
10	Proposed 2nd Sampling	No			
11	HW-25				
12	Ex. 6-PII				
13		Analyte		Result	Trigger
14		Methane	Tap only	65,000 ug/L	28,000 ug/L
15		Sodium	Tap only	24,700 ug/L	20,000 ug/L
16	EPA Alt. Water	No			
17	Cabot Alt. Water	No			
18	Treatment	No-owner installed methane vent @ wellhead			
19	Proposed EPA Water	No			
20	Proposed 2nd Sampling	No			
21	HW-26				
22	Ex. 6-PII				
23		Analyte		Result	Trigger
24		Methane	Wellhead	43,000 ug/L	28,000 ug/L
25		Methane	Tap	38,000 ug/L	28,000 ug/L
26		Sodium	Wellhead	27,400 ug/L	20,000 ug/L
27		Sodium	Tap	27,400 ug/L	20,000 ug/L
28		Sodium	Tap Filtered	27,800 ug/L	20,000 ug/L
29	EPA Alt. Water	No			
30	Cabot Alt. Water	No			
31	Treatment	?			
32	Proposed EPA Water	No			
33	Proposed 2nd Sampling	No			
34	HW-29				

	A	B	C	D	E
35	Ex. 6-PII				
36		Analyte		Result	Trigger
37		Methane	Wellhead only	77,000 ug/L	28,000 ug/L
38		Sodium	Wellhead only	195,000 ug/L	20,000 ug/L
39		Sodium	Wellhead - Filtered	201,000 ug/L	20,000 ug/L
40		Lithium	Wellhead only	478 ug/L	31 ug/L
41		Lithium	Wellhead - Filtered	493 ug/L	31 ug/L
42	EPA Alt. Water	No			
43	Cabot Alt. Water	Yes-serves both houses			
44	Treatment	No-Cabot well vent only			
45	Proposed EPA Water	No			
46	Proposed 2nd Sampling	No			
47					

	A	B	C	D	E
88	EPA Alt. Water	No			
89	Cabot Alt. Water	Yes			
90	Treatment	Yes-Cabot system incl RO/ vent?			
91	Proposed EPA Water	No			
92	Proposed 2nd Sampling	?			
93					

	A	B	C	D	E
94	HW-40				
95	Ex. 6-PII				
96		Analyte		Result	Trigger
97		Sodium	Wellhead	21,700 ug/L	20,000 ug/L
98		Sodium	Tap	21,200 ug/L	20,000 ug/L
99	EPA Alt. Water	No			
100	Cabot Alt. Water	No			
101	Treatment	Yes -Sediment filter only			
102	Proposed EPA Water	No			
103	Proposed 2nd Sampling	No			
104					
105	HW-41				
106	Ex. 6-PII				
107		Analyte		Result	Trigger
108		Sodium	Wellhead	23,100 ug/L	20,000 ug/L
109		Sodium	Tap	23,400 ug/L	20,000 ug/L
110		Sodium	Wellhead+Tap Filtered	23,600 ug/L	20, 000 ug/L
111	EPA Alt. Water	No			
112	Cabot Alt. Water	No			
113	Treatment	No			
114	Proposed EPA Water	No			
115	Proposed 2nd Sampling	No			